

**Lake Huron Water Treatment Plant
2017 Regulated Detected Contaminants Tables**

2017 Inorganic Chemicals – Monitoring at the Plant Finished Water Tap								
Regulated Contaminant	Test Date	Unit	Health Goal MCLG	Allowed Level MCL	Highest Level Detected	Range of Detection	Violation yes/no	Major Sources in Drinking Water
Fluoride	5-16-2017	ppm	4	4	0.72	n/a	no	Erosion of natural deposits; Water additive, which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate	5-16-2017	ppm	10	10	0.34	n/a	no	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Barium	5-16-2017	ppm	2	2	0.01	n/a	no	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits

2017 Disinfection By-Products – Monitoring in Distribution System, Stage 2 Disinfection By-Products								
Regulated Contaminant	Test Date	Unit	Health Goal MCLG	Allowed Level MCL	Highest LRAA	Range of Detection	Violation yes/no	Major Sources in Drinking Water
Total Trihalomethanes (TTHM)	2017	ppb	n/a	80	64	29.6 - 64	no	By-product of drinking water chlorination
Haloacetic Acids (HAA5)	2017	ppb	n/a	60	17	4 - 17	no	By-product of drinking water disinfection
Regulated Contaminant	Test Date	Unit	Health Goal MRDLG	Allowed Level MRDL	Highest RAA	Quarterly Range of Detection	Violation yes/no	Major Sources in Drinking Water
Total Chlorine Residual	Jan-Dec 2017	ppm	4	4	0.75	0.65-0.80	no	Water additive used to control microbes

2017 Turbidity – Monitored every 4 hours at Plant Finished Water				
Highest Single Measurement Cannot exceed 1 NTU	Lowest Monthly % of Samples Meeting Turbidity Limit of 0.3 NTU (minimum 95%)		Violation yes/no	Major Sources in Drinking Water
0.29 NTU	100 %		no	Soil Runoff
Turbidity is a measure of the cloudiness of water. We monitor it because it is a good indicator of the effectiveness of our filtration system.				

2017 Lead and Copper Monitoring at Customers' Tap								
Regulated Contaminant	Test Date	Unit	Health Goal MCLG	Action Level AL	90 th Percentile Value*	Number of Samples over AL	Violation yes/no	Major Sources in Drinking Water
Lead	2017	ppb	0	15	2	0		Corrosion of household plumbing system; Erosion of natural deposits.
Copper	2017	ppm	1.3	1.3	.6	1		Corrosion of household plumbing system; Erosion of natural deposits; Leaching from wood preservatives.

*The 90th percentile value means 90 percent of the homes tested have lead and copper levels below the given 90th percentile value. If the 90th percentile value is above the AL additional requirements must be met.

**Lake Huron Water Treatment Plant
2017 Regulated Detected Contaminants Tables**

Regulated Contaminant	Treatment Technique 2017	Typical Source of Contaminant
Total Organic Carbon (ppm)	The Total Organic Carbon (TOC) removal ratio is calculated as the ratio between the actual TOC removal and the TOC removal requirements. The TOC was measured each quarter and because the level was low, there is no TOC removal requirement	Erosion of natural deposits

Radionuclides 2014							
Regulated contaminant	Test date	Unit	Health Goal MCLG	Allowed Level	Level detected	Violation Yes/no	Major Sources in Drinking water
Combined Radium 226 and 228	5-13-14	pCi/L	0	5	0.86 + or - 0.55	no	Erosion of natural deposits

Contaminant	MCLG	MCL	Level Detected 2017	Source of Contamination
Sodium (ppm)	n/a	n/a	4.46	Erosion of natural deposits